



Certificate / Certificat Zertifikat / 合格証

SAM 2108032 C002

exida hereby confirms that the:

Trunnion Mounted Ball Valves

SAMAMAT Flow Control L.L.C Dubai - UAE

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-2

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer
may use the mark:



Revision 2.0 February 13, 2025
Surveillance Audit Due
November 1, 2027



Evaluating Assessor

Certifying Assessor

SAM 2108032 C002

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

PFH/PFD_{avg} and Architecture Constraints must be verified for each application

Systematic Capability:

These products have met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

Versions:

Valve Series	Sizes	Pressure Class
Trunnion Ball Valve – Side Entry	2" to 36"	ASME Class 150, 300, 600 and 900
	2" to 12"	ASME Class 1500, and 2500
Trunnion Ball Valve – Top Entry	2" to 24"	ASME Class 150, 300, 600 and 900
	2" to 12"	ASME Class 1500 and 2500

IEC 61508 Failure Rates in FIT*

Static Application	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Full Stroke, Clean Service	0	0	0	513
Tight Shut-Off, Clean Service	0	0	0	1060
Open on Trip, Clean Service	0	132	0	386

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: SAM 21/08-032 R003 V2 R1 (or later)

Safety Manual: SFC-SM-0002-00-02/25 (or later)

Trunnion Mounted
Ball Valves

